



Site Details: Bassingbourn-cum-Kneesworth Parish Council
The Old School Community Centre
53 High Street
Bassingbourn
Royston
Herts
SG8 5LD

Tel No:

Email:

We hereby certify that the emergency lighting system
(as applicable) has been serviced in accordance with BS5266-1: current editions

Certificate of Inspection

Emergency Lighting Maintenance

Emergency lights report

Works Done

29/06/2026 13:56:20 - Created by Andy Gray
Emergency lighting service

Emergency Lights		
Emergency light duration test		3 hour
% of emergency lights tested		100%
Emergency lighting suff..		Yes
All LED's on after service		Yes
Fire Logbook completed		No

Materials Used/Required:

Qty Part

Engineer

Customer

Andy Gray

29/06/2026 13:55:58

maisie

29/06/2026 13:56:08

Note:

The recommended period between successive inspection and service visits must not exceed six months for the fire alarm.

12 months for the emergency lighting.

If a risk assessment dictates more frequent service visits arrangements should be made.

If these recommendations are not implemented, it should be considered that the system is no longer compliant with this part of the BS 5839 or BS 5266 standards.